



**2024**  
**Annual Wastewater Report**  
**Lancaster Sewage Treatment**  
**Version 2.0**

Prepared by:

A handwritten signature in dark ink, appearing to read "Dillen Seguin", is written over a horizontal line.

Dillen Seguin  
Director of Water and Wastewater

February 18, 2025

Date

Approved by:

A handwritten signature in dark ink, appearing to read "Sarah McDonald", is written over a horizontal line.

Sarah McDonald, P. Eng.  
General Manager, Infrastructure Services

February 18, 2025

Date

---

## Table of Contents

1. Description of the Works	3
2. Rated Capacity	3
3. Effluent Objectives	5
4. Effluent Limits	5
5. Monitoring And Recording	6
6. Laboratory	6
7. 2024 Annual Effluent Quality	6
8. Inventory	7
9. Maintenance	7
10. Operational Issues	7
11. Biosolid (Sludge) Summary	7
12. Complaints	8
13. By-Pass Report(s)	8
14. Reports	8

## Revision History

Date	Description	Revision	Author
February 4, 2025	Initial Issue for Council Receipt	1.0	D. Seguin
February 18, 2025	Issued for Council Acceptance	2.0	D. Seguin

---

# Lancaster Sewage Treatment Plant

In accordance with the Certificate of Approval, Number 8124-4L9KB9, Issue date July 17, 2000 the Water Pollution Control Plant (WPCP) is required to prepare an annual performance report. This document covers the reporting year January 01 to December 31, 2024; the facility performance report summarizes important information regarding the quality of the effluent wastewater, analytical test results, maintenance operations, and relevant activities of the WPCP.

## 1. Description of the Works

Capacity of Works	1,490 m <sup>3</sup> /day (average daily flow)
Service Area	Village of Lancaster & South Lancaster
Service Population	Approximately 1,190
Effluent Receiver	Lake St. Francis
Major Process	Facultative Lagoon treatment facility complete with a phosphorus removal system


The Lancaster WPCP received and operates its operation under *Certificates of Approval (now referred to as Environmental Compliance Approval [ECA])* Number 8124-4L9KB9, in accordance with Section 53 of the Ontario Water Resources Act. The Certificate of Approval outlines the terms and conditions, and the report captures these terms and conditions in the following sections.

## 2. Rated Capacity

For the purposes of the ECA and the terms and conditions specified, the following definition applies: “*Rated Capacity*” means the *Average Daily Flow* for which the *Works* are approved to handle.

The rated capacity of the Lancaster WPCP is 1,490 cubic meters per day (m<sup>3</sup>/day); that is raw influent (flow) into the lagoon for treatment. During the reporting year 2024, the Lancaster WPCP exceeded the rated capacity of 1,490 m<sup>3</sup>/day, thirty-five (35) days.

### Monthly Average and Maximum Daily Flows for 2024 (Rated capacity 1,490 m<sup>3</sup>/day)



#### High Flow Events

August 2024 – Heavy Rain Event

### 3. Effluent Objectives

The owner and/or operating authority shall use *best efforts* to design, construct and operate the *Works* with the objective that the concentrations and loadings of the materials named below (Table 1) as effluent parameters are not exceeded in the effluent from the *Works*.

**Table 1. Effluent Best Efforts Limits as per ECA, condition 3.1**

Effluent Parameter	Average Concentration (milligrams per litre unless otherwise indicated)	Average Loading Objective (kilograms per day unless otherwise indicated)
Column 1	Column 2	Column 3
CBOD <sub>5</sub>	25	37.3
Total Suspended Solids	30	44.7
Total Phosphorus		
Summer – June 1 to November 30	0.4	0.60
Winter – December 1 to May 31	0.8	1.2
Total Ammonia Nitrogen:		
Summer – June 1 to November 30	11	16.4
Winter- December 1 to May 31	18	26.8
<i>E. Coli – May 1 to September 31</i>		-

### 4. Effluent Limits

The *Owner* shall operate and maintain the *Works* such that the concentrations and waste loadings of the materials named in Table 2 as effluent parameters are not exceeded in the effluent from the *Works*.

**Table 2. Effluent Limits as per C of A, conditions 1.4**

Effluent Parameter	Average Concentration (milligrams per litre unless otherwise indicated)	Average Loading Objective (kilograms per day unless otherwise indicated)
Column 1	Column 2	Column 3
CBOD <sub>5</sub>	30	44.7
Total Suspended Solids	40	59.6
Total Phosphorus		
Summer – June 1 to November 30	0.5	0.75
Winter – December 1 to May 31	1.0	1.5
Total Ammonia Nitrogen:		
Summer – June 1 to November 30	13	19.4
Winter- December 1 to May 31	20	30.0
<i>E. Coli – May 1 to September 31</i>		-

## 5. Monitoring And Recording

The *Owner* shall, upon commencement of operation of the *Works*, carry out the following the monitoring program.

**Effluent Monitoring** - (samples to be collected at the outlet of the disinfection facilities or at the outfall sewer as close as possible at the treatment plant).

Parameters	Sample Type	Frequency
CBOD <sub>5</sub>	24-hr composite	Bi-monthly
Total Suspended Solids	24-hr composite	Bi-monthly
Total Phosphorus	24-hr composite	Weekly
Total Ammonia Nitrogen	24-hr composite	Weekly
<i>E. Coli</i>	Grab	Weekly

## 6. Laboratory

Caduceon Environmental laboratories is contracted to conduct the required analytical tests of the influent (raw) and effluent samples, as per the ECA.

## 7. 2024 Annual Effluent Quality

In the reporting year 2024, the *Works* were operated and maintained such that the concentrations and waste loadings of the materials named in Table 2 as effluent parameters were not exceeded in the effluent from the *Works*; in compliance with the ECA requirements for the effluent limits parameters.

In addition, *best efforts* were achieved with the objective that the concentrations and loadings of the materials named above in **Table 1** as effluent parameters were not exceeded in the effluent from the *Works*.

Parameters	Average Concentration mg/L	Criteria Concentration mg/L	Average Loading kg/d	Loading Criteria kg/d
CBOD <sub>5</sub>	3.39	30	3.19	44.7
Total Suspended Solids	6.48	40	6.70	59.6
Total Phosphorus:				
Summer – June 1 to Nov 30	0.05	0.5	0.08	0.75
Winter – Dec 1 to May 31	0.20	1.0	0.20	1.5
Total Ammonia Nitrogen:				
Summer – June 1 to Nov 30	4.70	13	3.45	19.4
Winter- Dec 1 to May 31	12.74	20	13.18	30.0
<i>E. Coli</i>			-	-

## 8. Inventory

Chemical	Annual Status	Units
Alum	48,875	Cubic meters

## 9. Maintenance

The Operators performed the routine operations and maintenance at the treatment plant and pumping stations in accordance with the preventative maintenance program (report on file at plant). The activities are highlighted as follows:

Monthly	<ul style="list-style-type: none"> <li>Checked Operations and Performance of Sewage Pumps.</li> </ul>
Treatment Plant	<ul style="list-style-type: none"> <li>Changed Oil - Blower #1, #2 and #3</li> </ul>
Quarterly	<ul style="list-style-type: none"> <li>N/A</li> </ul>
Semi-Annually	<ul style="list-style-type: none"> <li>Cleaned Filters on Blower #1, #2 and #3.</li> </ul>
Annually	<ul style="list-style-type: none"> <li>Annual Calibration of Monitoring Equipment</li> <li>Annual Calibration of Flow Meters</li> </ul>
Major Maintenance	<ul style="list-style-type: none"> <li>Flow Sensor Replaced (Jan)</li> <li>Manta-ray Sent for Repair/Servicing (Feb)</li> <li>Third Party Blower Inspections (Mar)</li> <li>Effluent Inspection (May)</li> <li>Splitter Box Flushing (Jun)</li> <li>Lagoon Grass Cut (Jun)</li> <li>Pump Station Cleaning x 2 Stations (Jul)</li> <li>Install Overflow Pipe Between Cells (Sep)</li> <li>Manhole Grouting (Sep)</li> <li>CIPP Spot Repairs (Sep)</li> <li>Grouting (Sep)</li> <li>Steam Clean Alum Tank (Nov)</li> <li>Replace Gasket on Alum Tank (Nov)</li> </ul>

## 10. Operational Issues

There were no operational issues noted during 2024.

## 11. Biosolid (Sludge) Summary

The Glen Walter WPCP has a program in place for the removal of biosolids transferred from the Glen Walter W.P.C.P *Works to the Lancaster lagoons*; volume totaling 499 m<sup>3</sup> for the fiscal year 2024. Joseph Romeo René Goulet (Certificate of Approval Hauler # A 920463) is contracted and hauled/transported 499 m<sup>3</sup> to the Lancaster Lagoons for disposal.

The *Works* maintains haulage records for biosolids transferred from the Glen Walter WPCP to the Lancaster Lagoons; available upon request.

## 12. Complaints

No complaints reported during the 2024 operational year.

## 13. By-Pass Report(s)

By-passing occurrences: 1

### Spill/Overflow 1

Date:	June 24th, 2024
Asset:	Lancaster Lagoon
Location:	Rail Side Road
Reference Number:	1-831V90
Cause:	Blockage/Wet Weather
Volume:	72m3
Duration:	2hours
Disinfection:	None
Adverse Impact:	None
Grab Samples:	Yes

On June 24<sup>th</sup>, 2024, the splitter box between the aeration cell and lagoon cell had clogged with debris (Cattails/Phragmites). Flow continued to pass through the splitter box at a lower rate than the incoming raw sewage, causing the aeration cell to overflow. A bypass channel was created between both cells to eliminate the overflow. Channel remained open until operators could fix the issue within the splitter box and put back into normal operation. A 10" sewer pipe has been installed at a higher elevation to eliminate future spills, while operating the site as designed.

*\*All by-pass/overflows for the collection system(s) have been moved to the Municipal sewer collection report for 2024 and ongoing. However, bypass/overflows may still occur for the wastewater system facility(s).*

## 14. Reports

- Appendix A – Lancaster Sewage Annual Performance Report 2024 (Attached)
- Caduceon Environmental Laboratories Analytical Reports - (on-file at plant)
- Lancaster Daily/Monthly Report Summary - (on-file at plant)
- Lancaster Bypass Incident Report – (on-file at plant)



Water Course: Lake St. Francis  
Design Capacity: 1,490 x 1000 m3/D

Annual Report Data  
2024

Municipality: Township of South Glengarry  
Project: Lancaster Lagoons

Description: 2 Sewage Pumping Stations - 1 Aeration Cell - Facultative Treatment - Continuous Discharge

	Influent Flow			Effluent			Biochemical Oxygen Demand			Suspended Solids - Total			Phosphorus			Ammonium			Waste Loadings			Alum	
	Total X 1000 m3	Average X 1000 m3	Maximum Daily X 1000 m3	Flow - Total X 1000 m3/D	Average Influent mg/L	Average Effluent mg/L	Removal Percent	Average Influent mg/L	Average Effluent mg/L	Removal Percent	Average Influent mg/L	Average Effluent mg/L	Removal Percent	Average Influent mg/L	Average Effluent mg/L	Removal Percent	Average Influent mg/L	Average Effluent mg/L	BOD Kg/D	TSS Kg/D	N-NH3 Kg/D	Alum m3 Used	Effluent Flow Average m3/D
January	27,927	0.900	1.399	47,581	108.00	3.00	97.22	380.00	8.00	97.89	3.98	0.1	97.49	11.8	4.60	12.27	0.15	18.10	4.60	12.27	0.15	3.700	1,534
February	24,594	0.848	1.198	24,594	95.25	4.00	95.80	67.00	8.75	86.94	3.47	0.1	97.12	14.4	3.39	7.42	0.08	12.21	3.39	7.42	0.08	3.100	0,848
March	33,741	1.088	1.645	43,733	52.00	4.25	91.83	30.50	10.75	64.75	2.48	0.12	95.16	12.2	5.99	15.16	0.17	17.20	5.99	15.16	0.17	3.400	1,410
April	32,855	1.095	1.653	43,512	40.40	3.40	91.58	38.40	11.60	69.79	1.64	0.15	90.85	11.04	4.93	16.82	0.22	16.01	4.93	16.82	0.22	4.100	1,450
May	23,238	0.749	1.007	25,379	56.75	3.00	94.71	54.00	4.25	92.13	2.54	0.15	94.09	12.83	2.45	3.48	0.12	10.49	2.45	3.48	0.12	3.700	0,818
June	22,952	0.765	1.780	22,516	54.25	3.25	94.01	48.75	4.25	91.28	2.14	0.07	96.73	9.87	2.44	3.19	0.05	7.40	2.44	3.19	0.05	3.390	0,750
July	24,915	0.830	1.233	23,874	42.60	3.00	92.96	37.60	5.40	85.64	1.71	0.05	97.08	4.23	2.39	4.29	0.04	3.36	2.39	4.29	0.04	3.900	0,795
August	36,455	1.175	2.981	46,142	49.25	3.00	93.91	43.75	4.25	90.29	1.81	0.07	96.13	3.65	4.46	6.32	0.10	5.43	4.46	6.32	0.10	4.380	1,488
September	16,053	0.535	0.774	15,988	121.75	3.00	97.54	174.50	3.00	98.28	3.66	0.05	98.63	1.11	1.60	1.60	0.03	0.59	1.60	1.60	0.03	4.950	0,532
October	12,681	0.409	0.596	7,651	200.00	3.00	96.50	605.00	4.40	99.27	10.26	0.06	99.42	2.43	0.74	1.08	0.01	0.60	0.74	1.08	0.01	5.100	0,246
November	12,700	0.423	0.505	14,302	179.00	3.75	97.91	248.00	7.25	97.08	7.22	0.18	97.51	6.92	1.79	3.45	0.09	3.29	1.79	3.45	0.09	5.380	0,476
December	21,589	0.696	1.109	27,516	139.00	4.00	97.12	215.00	6.00	97.21	5.02	0.28	94.42	13.04	3.55	5.32	0.25	11.57	3.55	5.32	0.25	3.775	0,887
Total	289,695			342,788											38.32	80.40	1.32	106.26	38.32	80.40	1.32	48.875	11,234
Average	24,142	0.793	1.323	28,566	94.85	3.39	95.26	161.88	6.49	89.21	3.83	0.12	96.22	8.63	3.19	6.70	0.11	8.86	3.19	6.70	0.11		
Criteria		1.49				30			40			S 0.5		S 13	44.7	59.6	S 0.75	S 19.4	44.7	59.6	S 0.75		
Maximum		1.175				3.39			6.49			W 1.0		W 20			W 1.5	W 30			0.11		
Compliance		Yes			Yes	Yes			Yes		Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

<b>Lagoon pH Samples 2024</b>												
<b>Month</b>	<b>Jan</b>	<b>Feb</b>	<b>Mar</b>	<b>Apr</b>	<b>May</b>	<b>Jun</b>	<b>Jul</b>	<b>Aug</b>	<b>Sep</b>	<b>Oct</b>	<b>Nov</b>	<b>Dec</b>
<b>Avg.</b>	7.75	7.44	7.82	8.40	7.88	7.82	7.49	7.36	7.56	7.44	7.18	7.14
1		7.46			8.00					7.38		
2	7.10			8.50	7.53		7.41			7.45		7.10
3	7.80			8.50		7.90	7.57		7.15	7.80		7.03
4	8.10		7.32	8.50		8.10	7.33		7.80		7.46	6.97
5		7.33	7.37			8.10			7.69		7.29	
6			7.35		7.90	8.10		7.31			7.35	
7		7.49	7.38		7.80			7.47		7.43		
8	8.00	7.47		8.60	7.80		7.17	7.71		7.37		
9	8.00			8.50	7.80		7.13		7.60	7.32		7.21
10	8.00			8.50		8.90	7.10		7.86	7.23		7.06
11			7.5	8.50		8.00	7.34		7.83			7.10
12		7.47	7.7			8.00		7.36			7.35	
13		7.47	7.64		7.46	8.00		7.36			7.08	
14		7.49	7.9					7.77			7.05	
15	7.9			8.48			7.56			7.28		
16	8.00			8.50	7.90		7.71		7.73	7.52		7.02
17	7.54			8.40	7.90	7.90	7.26		7.44	7.28		7.00
18	7.90		7.95	8.40		7.20			7.48		7.15	6.85
19			8.00			7.30		7.41			7.16	
20		7.44	8.04			7.00		7.44			7.01	
21		7.55	8.20		7.90			7.19		7.30		
22	7.90	7.55		8.30	8.10		7.63			7.54		
23	7.40				8.00		7.59		7.36	7.37		7.80
24	7.56			8.30		7.49	8.11					7.64
25		7.51	8.30	8.20		7.80			7.36		7.08	
26		7.34	8.30			7.48		7.26	7.37			7.20
27		7.19	8.30		8.00			7.31			7.19	
28					7.90			6.74		7.53	7.03	
29	7.58			8.10	8.00		7.77			7.62		
30				8.10	8.10		7.47			7.65		6.87
31	7.44						7.75					