



2024
Annual Drinking Water Report
and
Summary Report for Municipalities

Lancaster Water Treatment

Version 2.0

Prepared by:

A handwritten signature in dark ink, appearing to read "Dillen Seguin", is positioned above a horizontal line.

Dillen Seguin
Director of Water and Wastewater

February 18, 2025

Date

Approved by:

A handwritten signature in dark ink, appearing to read "Sarah McDonald", is positioned above a horizontal line.

Sarah McDonald, P. Eng.
General Manager, Infrastructure Services

February 18, 2025

Date

Table of Contents

| | |
|------------------------------|---|
| 1. Flows | 3 |
| 2. Compliance | 5 |
| 3. System Description | 5 |
| 4. Operation Summary | 6 |
| 5. Non-Compliance | 7 |
| 6. Regulatory Sample Results | 8 |

Regulations

Annual Report

O. Reg. 170/03 – Section 11

Summary Report for Municipalities

O. Reg. 170/-3 – Schedule 22


Revision History

| Date | Description | Revision | Author |
|-------------------|-----------------------------------|----------|-----------|
| February 4, 2025 | Initial Issue for Council Receipt | 1.0 | D. Seguin |
| February 18, 2025 | Issued for Council Acceptance | 2.0 | D. Seguin |
| | | | |
| | | | |

Lancaster Water Treatment Plant – Annual Report

1. Flows

Daily Average and Maximum Raw Daily Flows



Permit To Take Water (6653-AP9H6L)

| | |
|-------------------------------|-----------|
| Max Allowable Raw Water Flow: | 1,440m³/d |
| Year Max: | 978m³/day |


Note(s):

- Above Normal Usage x 1

January – High Water Flow Caused Due to Fire Hydrant

July – Flush of System

Daily Average and Maximum Treated Daily Flows



Municipal Drinking Water License Rated Capacity (185-101)

| | |
|--------------------------------------|------------------------|
| Max Allowable Raw Water Flow: | 1,440m ³ /d |
| Year Max: | 876m ³ /day |

Note(s):

- Above Normal Usage x 1

January – High Water Flow Caused Due to Fire Hydrant

July – Flush of System via Hydrant

2. Compliance

A written report is prepared annually. This report is available for viewing at the Township of South Glengarry Municipal office, 6 Oak Street Lancaster or at the Glen Walter Water Treatment Plant located at 18352 County Road 2 in Glen Walter. A copy of the report is also available on the Townships web site. A copy of the report is available free of charge to any resident requesting a copy. For more information on the Municipal water supply contact:

Township of South Glengarry
Water/Wastewater Division
Telephone: 613-931-3036
Fax: 613-931-3340
E-mail: infrastructure@southglengarry.com

The Township of South Glengarry commitment policy is to provide a safe and reliable supply of drinking water to all its customers, meet or exceed the requirements of all legislation and regulations applicable to drinking water and maintain and continually improve its quality management system.

3. System Description

Overview

The Township of South Glengarry, Lancaster Water Treatment Plant is located at **20523 Old Montreal Road in South Lancaster**. The water treatment plant is a surface water treatment facility serving the village of Lancaster and the Hamlet of South Lancaster. The water plant has a rated capacity of 1,440 cubic meters of water per day for a design population of 1,218 people.

The Township of South Glengarry utilizes the following accredited laboratory to ensure safe and potable water to meet or exceed Ministry standards: Caduceon Laboratory Ottawa.

The Township of South Glengarry operators are all certified under the Ministry of the Environment regulation 128/04 for utility Operator Licensing Program.

The Township of South Glengarry water system uses Sodium Hypochlorite for disinfection and Aluminum Sulphate for a coagulant.

Equipment

Raw water is consumed through a 450 millimeter intake pipe and wooden intake crib off the shore of Lake St. Francis at a depth of approximately 12 meters. The plant consists of three low lift pumps rated at 8.33 liters per second one dual media anthracite sand gravity filter, one gravity granular activated carbon filter, three high lift pumps two rated at 15.9 liters per second and the third at 6.3 liters per second and two backwash pumps together with all associated piping, electrical equipment, controls and alarm systems all housed in a common building.

Process

Raw water is pumped from the low lift chamber, which is pre chlorinated. A liquid coagulant is introduced into an in line flash mixer, and then flows to two set of coagulant/flocculators;

clarifiers and filters each rated at 720 cubic meters per day. The filtered water is then post chlorinated before it enters the twin celled reservoir. The treated (potable) water is then pumped to the distribution system and also feeds an elevated storage tank located on North Beech Street.

Distribution

The distribution system is comprised of varying sized water pipes, valves, and fire hydrants all supplied from the three high lift pumps situated at the Lancaster Water Plant. Fire flow can be achieved for the Lancaster Water system.

4. Operation Summary

There were no upgrades noted in the reporting year. Operational issues noted for the reporting year are outlined with all of the work completed within the Table 1. Major Maintenance (2024).

The major maintenance undertaken on the Lancaster system is provided in the table below.

Table 1. Major Maintenance (2024)

| 2024 | Details |
|------|--|
| Jan. | Hypo Pump Tubes Changed |
| Jan. | Heaters Failed x 2 Fixed/Replaced |
| Jan. | Hydrant Opened Causing Low Clearwell and Tower |
| Feb | PRV Replaced on Alum Dosage System |
| Feb. | Building Pipe Envelopes Clogged (Reamed) |
| Feb. | Chemical Containment Area Cleaned |
| May | Spring Hydrant Flushing |
| May. | Valve Exercising Started |
| May. | Intake Inspection |
| Jun. | Analytical Calibrations Third Party |
| Jun. | Generator Maintenance/Tests |
| Aug. | Tile Work in Lancaster Lab |
| Aug. | Scada Failure Corrupted Computer Drive |
| Sep. | Water Tower Inspection |
| Oct. | Fall Flush and Residual Checks |
| Oct. | Flow Meter Calibrations |
| Oct. | Winterize Hydrants |
| Dec. | Scheduled Power Outage Affecting Plants |
| Dec. | Generator Maintenance/Load Test |

Lancaster Water Treatment Plant – Summary Report

Ontario Drinking Water License #185-101

The Township of South Glengarry Water Treatment Department operated the Lancaster Water Treatment Plant for the year 2024.

5. Non-Compliance

Adverse Water Quality Incidents

During the reporting year, there were no adverse water quality incidents (AWQI).

Incident #1 (none)

| | |
|-------------------------|---|
| Incident Date: | - |
| Parameter: | - |
| Result: | - |
| Corrective Action: | - |
| Corrective Action Date: | - |
| Corrective Compliance: | - |

Non-Compliance

During the reporting year, there was no non-compliance in regard to a regulatory requirement.

Non-Compliance #1 (none)

| | |
|-------------------------|---|
| Non-Compliance Date: | - |
| Parameter: | - |
| Result: | - |
| Corrective Action: | - |
| Corrective Action Date: | - |
| Corrective Compliance: | - |

Non-Compliance Ministry Inspection

During the year 2024, there were no non-compliance from a ministry inspection within the Lancaster Drinking Water System.

The ministry inspection occurred on and off site during the month of July. There were no issues of regulatory compliance identified in the report and the final inspection rating was 100%. A copy of the report is available at The Glen Walter Water Treatment Plant Office.

6. Regulatory Sample Results

Statistics for Flow and Chemicals

A total of 145,255m³ of raw water had been treated for the year 2024 with a monthly average of 396m³ per day and a maximum flow of 876m³ /day for the year. Maximum flow is equivalent to 61% of plant capacity. It is noted that one (1) high usage days occurred and were not regular flow operations.

The Lancaster Water Treatment Plant uses sodium hypochlorite for disinfection. A total of 727.41kg of sodium hypochlorite has been utilized for the year at an average dosage rate of 5.01mg/litre.

The Lancaster Water Treatment Plant also uses aluminum sulphate as a coagulant in the treatment process. A total of 2.970m³ of aluminum sulphate had been used.

Attached is the data spread sheet, which identifies flows, laboratory results, number of samples collected and chemical use on a monthly basis.

Municipality: Township of South Glengarry
Project: Lancaster W.T.P
DWS # 260006867

Annual Report Data
2024

Water Source: Lake St. Francis
Design Capacity: 1.440 x 1000 m3/D

Description: Conventional Treatment - Chemically Assisted Filtration (Alum) - Sodium Hypochlorite Disinfection

| | Raw Water Flow | | | Treated Water Flow | | | Chemical Usage | | Treated Water | | | | | | | Distribution Water | | | | | | | | |
|------------|--------------------|----------------------|-------------------------------|--------------------|----------------------|-------------------------------|----------------------|----------------------|--|------|------|-----------------------------|--------------------------|-----------------------------|---------------------|---------------------|--|------|------|----------|-----------|-----------|---------|----|
| | Total X 1000 m3 | Average X 1000 m3 | Maximum Daily X 1000 m3 | Total X 1000 m3 | Average X 1000 m3 | Maximum Daily X 1000 m3 | Cl2 Total Kg Used | Alum Total L Used | Free Cl2 Residual mg/L Min. Max. Avg. | | | Average Turbidity NTU | Average Colour TCU | Average Aluminum mg/L | Nitrate NO3 mg/L | Nitrite NO2 mg/L | Free Cl2 Residual mg/L Min. Max. Avg. | | | THM ug/L | Lead ug/L | Lead ug/L | | |
| January | 10.264 | 0.331 | 0.892 | 9.316 | 0.300 | 0.698 | 45.45 | 232.560 | 0.80 | 2.27 | 1.78 | 0.13 | | 0.050 | 0.28 | 0.5 | 0.84 | 1.90 | 1.57 | | 43 | | | |
| February | 10.097 | 0.348 | 0.534 | 8.931 | 0.307 | 0.432 | 37.85 | 199.260 | 1.64 | 2.61 | 2.00 | 0.13 | | 0.030 | | | 1.55 | 2.00 | 1.82 | | | | | |
| March | 10.516 | 0.339 | 0.488 | 9.902 | 0.319 | 0.466 | 46.93 | 222.420 | 1.74 | 2.16 | 1.90 | 0.11 | | 0.020 | | | 1.64 | 2.00 | 1.77 | | | | | |
| April | 11.025 | 0.367 | 0.513 | 10.161 | 0.338 | 0.484 | 45.35 | 223.080 | 1.68 | 2.04 | 1.91 | 0.13 | | 0.030 | 0.29 | 0.05 | 1.60 | 1.90 | 1.80 | | 38 | | | |
| May | 14.098 | 0.454 | 0.656 | 12.535 | 0.404 | 0.628 | 55.82 | 285.780 | 1.75 | 2.11 | 1.92 | 0.13 | | 0.060 | | | 1.64 | 1.90 | 1.73 | | | | | |
| June | 14.815 | 0.493 | 0.680 | 13.443 | 0.448 | 0.589 | 76.15 | 274.560 | 1.44 | 2.15 | 1.79 | 0.090 | | 0.100 | | | 1.36 | 1.86 | 1.61 | | | | | |
| July | 16.391 | 0.528 | 0.978 | 14.930 | 0.481 | 0.876 | 91.14 | 349.140 | 1.29 | 2.30 | 1.74 | 0.09 | | 0.130 | 0.2 | 0.05 | 1.14 | 1.82 | 1.50 | | 70 | | | |
| August | 14.047 | 0.453 | 0.638 | 12.626 | 0.407 | 0.614 | 97.97 | 290.400 | 1.60 | 2.17 | 1.87 | 0.08 | | 0.220 | | | 1.48 | 1.80 | 1.65 | | | | | |
| September | 10.928 | 0.364 | 0.541 | 10.088 | 0.336 | 0.485 | 59.68 | 225.060 | 1.53 | 2.31 | 2.02 | 0.090 | | 0.170 | | | 1.52 | 1.96 | 1.80 | | | | | |
| October | 11.271 | 0.363 | 0.531 | 10.129 | 0.326 | 0.476 | 63.46 | 224.400 | 1.78 | 2.20 | 1.97 | 0.070 | | 0.130 | 0.11 | 0.05 | 1.74 | 1.98 | 1.84 | | 54 | | | |
| November | 10.953 | 0.365 | 0.548 | 10.047 | 0.334 | 0.507 | 50.86 | 225.060 | 1.73 | 2.18 | 1.94 | 0.08 | | 0.070 | | | 1.68 | 2.00 | 1.85 | | | | | |
| December | 10.850 | 0.350 | 0.497 | 9.990 | 0.322 | 0.492 | 56.75 | 218.460 | 1.11 | 2.09 | 1.88 | 0.090 | | 0.050 | | | 1.06 | 1.88 | 1.71 | | | | | |
| Total | 145.255 | | | 132.098 | | | 727.41 | 2970.18 | | | | | | | | | | | | | | | | |
| Average | 12.104583 | 0.396 | 0.625 | 11.008 | 0.360 | 0.562 | 60.62 | 247.515 | 1.51 | 2.22 | 1.89 | 0.10 | | 0.088 | 0.2 | 0.1625 | 1.44 | 1.92 | 1.72 | | 51.3 | #DIV/0! | #DIV/0! | |
| Criteria | | | 1.440 | | | | | | 0.2 | | | | | | 10 | 1 | 0.05 | | | | | 100 | 10 | 10 |
| Maximum | | | 0.978 | | | 0.876 | | | 0.80 | | | | | | | | 0.84 | | | | | 51.3 | | |
| Compliance | | | Yes | | | | | | Yes | | | | | | Yes | Yes | Yes | | | | Yes | | | |

| | Total # of Raw Samples | Raw Water Escherichia Coliform (cfu/100mL) | | | Raw Water Total Coliform (cfu/100mL) | | | Total # of Treated Samples | Treated Water Escherichia Coliform (cfu/100mL) | | Treated Water Total Coliform (cfu/100mL) | | Treated Water Heterotrophic Plate Count (cfu/100mL) | | Total # of Dist. Samples | Distribution Water Escherichia Coliform (cfu/100mL) | | Distribution Water Total Coliform (cfu/100mL) | | Distribution Water Heterotrophic Plate Count (cfu/100mL) | |
|-----------|------------------------------|---|---------|---------|---|---------|---------|----------------------------------|--|--------|---|--------|---|--------|--------------------------------|---|--------|---|--------|--|--------|
| | | Minimum | Maximum | Average | Minimum | Maximum | Average | | Safe | Unsafe | Safe | Unsafe | Safe | Unsafe | | Safe | Unsafe | Safe | Unsafe | Safe | Unsafe |
| January | 5 | 0 | 0 | 0.00 | 1 | 10 | 2.20 | 5 | 5 | 0 | 5 | 0 | 5 | 0 | 15 | 15 | 0 | 15 | 0 | 15 | 0 |
| February | 4 | 0 | 0 | 0.00 | 1 | 5 | 2.25 | 4 | 4 | 0 | 4 | 0 | 4 | 0 | 12 | 12 | 0 | 12 | 0 | 12 | 0 |
| March | 4 | 0 | 0 | 0.00 | 0 | 2 | 1.00 | 4 | 4 | 0 | 4 | 0 | 4 | 0 | 12 | 12 | 0 | 12 | 0 | 12 | 0 |
| April | 5 | 0 | 1 | 0.20 | 1 | 6 | 2.40 | 5 | 5 | 0 | 5 | 0 | 5 | 0 | 15 | 15 | 0 | 15 | 0 | 15 | 0 |
| May | 4 | 0 | 0 | 0.00 | 4 | 6 | 2.50 | 4 | 4 | 0 | 4 | 0 | 4 | 0 | 12 | 12 | 0 | 12 | 0 | 12 | 0 |
| June | 4 | 0 | 0 | 0.00 | 1 | 2 | 0.75 | 4 | 4 | 0 | 4 | 0 | 4 | 0 | 12 | 12 | 0 | 12 | 0 | 12 | 0 |
| July | 5 | 1 | 2 | 0.80 | 1 | 8 | 2.60 | 5 | 5 | 0 | 5 | 0 | 5 | 0 | 15 | 15 | 0 | 15 | 0 | 15 | 0 |
| August | 4 | 0 | 11 | 3.50 | 12 | 220 | 85.25 | 4 | 4 | 0 | 4 | 0 | 4 | 0 | 12 | 12 | 0 | 12 | 0 | 12 | 0 |
| September | 4 | 1 | 14 | 4.75 | 2 | 154 | 54.00 | 4 | 4 | 0 | 4 | 0 | 4 | 0 | 12 | 12 | 0 | 12 | 0 | 12 | 0 |
| October | 5 | 1 | 6 | 3.00 | 8 | 28 | 18.80 | 5 | 5 | 0 | 5 | 0 | 5 | 0 | 15 | 15 | 0 | 15 | 0 | 15 | 0 |
| November | 4 | 2 | 6 | 4.25 | 14 | 30 | 27.00 | 4 | 4 | 0 | 4 | 0 | 4 | 0 | 12 | 12 | 0 | 12 | 0 | 12 | 0 |
| December | 5 | 0 | 4 | 2.20 | 6 | 124 | 55.60 | 5 | 5 | 0 | 5 | 0 | 5 | 0 | 15 | 15 | 0 | 15 | 0 | 15 | 0 |
| Total | 53 | | | | | | | 53 | | | | | | | 159 | | | | | | |

Inorganic Parameters**LANCASTER WATER TREATMENT PLANT**

| INORGANIC PARAMETERS | | | | | |
|-----------------------------|--------------------|---------------------|------------|------------------------|-------------------|
| PARAMETER | SAMPLE DATE | RESULT VALUE | MAC | UNIT OF MEASURE | EXCEEDANCE |
| ANTIMONY | Jan-02-24 | 0.000100 | 0.006 | mg/L | No |
| ARSENIC | Jan-02-24 | 0.000300 | 0.025 | mg/L | No |
| BARIUM | Jan-02-24 | 0.021000 | 1 | mg/L | No |
| BORON | Jan-02-24 | 0.017000 | 5 | mg/L | No |
| CADMIUM | Jan-02-24 | 0.000015 | 0.005 | mg/L | No |
| CHROMIUM | Jan-02-24 | 0.001000 | 0.050 | mg/L | No |
| LEAD | Year 2023 | 0.001035 | 10 | ug/L | No |
| MERCURY | Jan-02-24 | 0.000020 | 0.001 | mg/L | No |
| SELENIUM | Jan-02-24 | 0.001000 | 0.010 | mg/L | No |
| SODIUM | Aug 22 2022 | 17.800000 | 200 | mg/L | No |
| URANIUM | Jan-02-24 | 0.000190 | 0.020 | mg/L | No |
| FLUORIDE | Aug 22 2022 | 0.100000 | 1.5 | mg/L | No |
| NITRITE | Year 2024 | 0.162500 | 1 | mg/L | No |
| NITRATE | Year 2024 | 0.200000 | 10 | mg/L | No |

Eastern Ontario Health Unit MAC

| | | | | | |
|--------|-------------|------|----|------|----|
| Sodium | Aug 22 2022 | 17.8 | 20 | mg/L | No |
|--------|-------------|------|----|------|----|

Organic Parameters**LANCASTER WATER TREATMENT PLANT**

| ORGANIC PARAMETERS | | | | | |
|--|--------------------|---------------------|------------|------------------------|-------------------|
| PARAMETER | SAMPLE DATE | RESULT VALUE | MAC | UNIT OF MEASURE | EXCEEDANCE |
| ALACHLOR | Jan-02-24 | 0.30 | 5 | ug/L | No |
| ATRAZINE + N-DEALKYLATED METOBOLITES | Jan-02-24 | 0.50 | 5 | ug/L | No |
| AZINPHOS-METHYL | Jan-02-24 | 1.00 | 20 | ug/L | No |
| BENZO(A)PYRENE | Jan-02-24 | 0.01 | 0.01 | ug/L | No |
| BENZENE | Jan-02-24 | 0.50 | 5 | ug/L | No |
| BROMOXYNIL | Jan-02-24 | 0.50 | 5 | ug/L | No |
| CARBON TETRACHLORIDE | Jan-02-24 | 0.20 | 5 | ug/L | No |
| CARBARYL | Jan-02-24 | 3.00 | 90 | ug/L | No |
| CARBOFURAN | Jan-02-24 | 1.00 | 90 | ug/L | No |
| CHLORPYRIFOS | Jan-02-24 | 0.50 | 90 | ug/L | No |
| 1,2-DICHLOROBENZENE | Jan-02-24 | 0.50 | 200 | ug/L | No |
| 1,4-DICHLOROBENZENE | Jan-02-24 | 0.50 | 5 | ug/L | No |
| 1,2-DICHLOROETHANE | Jan-02-24 | 0.50 | 5 | ug/L | No |
| 1,1-DICHOETHENE | Jan-02-24 | 0.50 | 1.4 | ug/L | No |
| DICHLOROMETHANE | Jan-02-24 | 5.00 | 50 | ug/L | No |
| DIAZINON | Jan-02-24 | 1.00 | 20 | ug/L | No |
| DICAMBA | Jan-02-24 | 1.00 | 120 | ug/L | No |
| 2-4 DICHLOROPHENOL | Jan-02-24 | 0.20 | 900 | ug/L | No |
| 2,4-DICHLOROPHENOXY ACETIC ACID(2,4-D) | Jan-02-24 | 1.00 | 100 | ug/L | No |
| DICLOFOP-METHYL | Jan-02-24 | 0.90 | 9 | ug/L | No |
| DIMETHOATE | Jan-02-24 | 1.00 | 20 | ug/L | No |
| DIQUAT | Jan-02-24 | 5.00 | 70 | ug/L | No |
| DIURON | Jan-02-24 | 5.00 | 150 | ug/L | No |
| GLYPHOSATE | Jan-02-24 | 25.00 | 280 | ug/L | No |
| MALATHION | Jan-02-24 | 5.00 | 190 | ug/L | No |
| METOLACHLOR | Jan-02-24 | 3.00 | 50 | ug/L | No |
| METRIBUZIN | Jan-02-24 | 3.00 | 80 | ug/L | No |
| PARAQUAT | Jan-02-24 | 1.00 | 10 | ug/L | No |
| PENTACHLOROPHENOL | Jan-02-24 | 0.20 | 60 | ug/L | No |
| PHORATE | Jan-02-24 | 0.30 | 2 | ug/L | No |
| PICLORAM | Jan-02-24 | 5.00 | 190 | ug/L | No |
| POLYCHLORINATED BIPHENYLS(PCB) | Jan-02-24 | 0.05 | 3 | ug/L | No |
| PROMETRYNE | Jan-02-24 | 0.10 | 1 | ug/L | No |
| SIMAZINE | Jan-02-24 | 0.50 | 10 | ug/L | No |
| TETRACHLOROETHYLENE | Jan-02-24 | 0.50 | 30 | ug/L | No |
| TRICHLOROETHYLENE | Jan-02-24 | 0.50 | 5 | ug/L | No |
| TERBUFOS | Jan-02-24 | 0.50 | 1 | ug/L | No |
| 2,3,4,6-TRICHLOROPHENOL | Jan-02-24 | 0.20 | 5 | ug/L | No |
| TRIALATE | Jan-02-24 | 10.00 | 230 | ug/L | No |
| 2,4,6-TRICHLOROPHENOL | Jan-02-24 | 0.20 | 5 | ug/L | No |
| Vinyl Chloride | Jan-02-24 | 0.20 | 2 | ug/L | No |
| TRIFLURALIN | Jan-02-24 | 0.50 | 45 | ug/L | No |
| MCPA | Jan-02-24 | 10.00 | 100 | ug/L | No |
| THM (NOTE: SHOW LATEST ANNUAL AVERAGE) | Year 2024 | 51.3 | 100 | ug/L | No |
| HAA | Year 2024 | 24.0 | 80 | ug/L | No |